



TC-12119
Telephone:0484-2623576
email:-qcldaluva@gmail.com

KERALA WATER AUTHORITY

QUALITY CONTROL DISTRICT LAB,ALUVA -683101

WATER TEST-BACTERIOLOGY REPORT

Report No: ALY/B/9373

Report Issue Date: 03.11.2025

Customer Name & Address		Date of Receipt of Payment	23.10.2025	
SIVAGIRI VIDHYA NIKETHAN SENIOR SECONDARY SCHOOL THOTTUMUGHAM ALUVA		Date of Sample received	24.10.2025	
		Sample given by	MO FHC KEEZHMADU	
		Sample Code	ALY/B/9373	
		Sample Name	Drinking Water	
		Sample Condition	Good	
		Source of Sample	WELL	
		Sample Quantity	250ml	
		Test performing dates :		From :24.10.25 to 25.10.25
Sl. No.	Parameter	Acceptable Limit as per IS 10500-2012	Test Method	Result
1	Total Coliform	Shall not be Detected/100ml	IS15185-2016 (Reaffirmed 2021)	Absent
2	E-Coli	Shall not be Detected/100ml	IS15185-2016 (Reaffirmed 2021)	Absent

- NB:-1) The result stated above related only to the sample(s) submitted for testing by the customer .
2) The samples retain for 15 days from the end date of analysis
3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory


Analyzed By

[Signature]

Authorized By

[Signature]

End of Report



Issue Date : 04.10.2020

Rev.Date : 15/07/2025

Page 3 of 3

QUALITY MANAGER
KWA, QUALITY CONTROL DISTRICT
ERNAKULAM, ALUVA - 683 101